



Dt-15-12-23

Solapur Municipal Corporation, Solapur
Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appaszheb varad Peth, Solapur-413003

Email :- smcphewtr@gmail.com

Tel.No.0217-2740350

Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	DIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clean	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU).	2.9	0.3	1.0	5.0
4	pH Values	6.89	7.14	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	72.97	69.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	200	190	200	600
8	Alkalinity (as CaCO ₃)	110	100	200	600
9	Total Dissolved solids	284	292	500	2000
10	Residual chlorine	—	4.0		
11	Dissolved Oxygen	—		6.5	8.0
12	Electrical conductivity	—			
13	Temperature	—			
14	Bacterial count (MPN)	16	0		

S.D.Jadhav
Chemist
Bhavani Peth WTP