



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - smphewtr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA-11406

दि. 20/2/2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.9	0.8	1.0	5.0
4	pH Values	8.26	7.86	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	309.95	302.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	420	410	200	600
8	Alkalinity (as CaCO ₃)	320	315	200	600
9	Total Dissolved Solids	1021	1026	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.6	6.4	6.5	8.0
11	Electrical conductivity	-	-		
12	Temperature	-	-		
13	Bacterial count (MPN)	4 + + +ve	no any change		

R.S.H.
Chemist

Soregaon WTP