



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhayan, Railway line, punyashlok appasaheb, varad path, Solapur-413003


Email - snldphewtr@gmail.com

Tel.no: 0217-2740350

D106/01/2024

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Suspended particles	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.6	1.0	5.0
4	pH Values	8.0	7.5	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	90	80	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	210	170	200	600
8	Alkalinity (as CaCO ₃)	180	140	200	600
9	Total Dissolved Solids	266	270	500	2000
10	Residual chlorine	-	4 ppm		


Chemist
Pakani WTP