



Dt. 01.03.2023

Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasheeb varad Peth, Solapur-413003

Email :- smcphewtr@gmail.com

Tel.No.0217-2740350

Water Testing Report Dhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	DIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Colourless	colourless		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU).	2.5	0.3	1.0	5.0
4	pH Values	7.28	7.05	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	64.98	59.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	210	200	200	600
8	Alkalinity (as CaCO ₃)	90	80	200	600
9	Total Dissolved solids	268	279	500	2000
10	Residual chlorine	-	4.0		
11	Dissolved Oxygen	-		6.5	8.0
12	Electrical conductivity	-			
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav

Chemist

Bhavani Peth WTP