



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Email - smcpheutr@gmail.com Tel.no.0217-2740350

PHE/BHIMA-1413

दि. 25/2/2021

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.8	0.6	1.0	5.0
4	pH Values	8.01	7.72	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	312.95	309.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	415	410	200	600
8	Alkalinity (as CaCO ₃)	300	290	200	600
9	Total Dissolved Solids	1052	1059	500	2000
10	Residual chlorine	-	4.2	--	--
10	Dissolved oxygen	3.0	6.7	6.5	8.0
11	Electrical conductivity	-	-		
12	Temperature	-	-		
13	Bacterial count (MPN)	16	0		

R.S.

Chemist

Soregaon WTP