



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - smcphewtr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA- 950

दि. 24/11/2023

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.9	0.6	1.0	5.0
4	pH Values	8.16	7.62	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	299.95	294.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	380	375	200	600
8	Alkalinity (as CaCO ₃)	270	265	200	600
9	Total Dissolved Solids	820	826	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	2.1	6.1	6.5	8.0
11	Electrical conductivity	0.84	0.82		
12	Temperature	-	-		
13	Bacterial count (MPN)	-	-		

R.S.

Chemist
Soregaon WTP