



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email – [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA- 926

दि. 5/1 /2022

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.92	0.61	1.0	5.0
4	pH Values	8.16	7.63	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	249.95	244.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	350	340	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	270	265	200	600
9	Total Dissolved Solids	709	714	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	2.1	6.3	6.5	8.0
11	Electrical conductivity	1.64	1.62		
12	Temperature	-	-		
13	Bacterial count (MPN)	3 + + +ve	no any change		

R.S. /  
Chemist

Soregaon WTP