



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Tel.no.0217-2740350
Email - smepheotr@gmail.com

PHE/BHIMA- 938

दि. 16/1/2023

Water testing report of Soregnon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	6.2	0.7	1.0	5.0
4	pH Values	8.16	7.63	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	284.95	280.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	340	330	200	600
8	Alkalinity (as CaCO ₃)	260	250	200	600
9	Total Dissolved Solids	780	786	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	2.1	6.3	6.5	8.0
11	Electrical conductivity	1.74	1.69		
12	Temperature	-	-		
13	Bacterial count (MPN)	-	-		

RS