



Dt- 22-07-2023

## Solapur Municipal Corporation, Solapur

### Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasheeb varad Peth, Solapur-413003

Email :- [smcphewr@gmail.com](mailto:smcphewr@gmail.com)

Tel.No.0217-2740350

## Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clean	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.4	0.4	1.0	5.0
4	pH Values	7.08	6.95	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	79.97	72.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	230	220	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	120	110	200	600
9	Total Dissolved solids	210	200	500	2000
10	Residual chlorine	-	4.0	-	-
11	Dissolved Oxygen	-	-	6.5	8.0
12	Electrical conductivity	-	-	-	-
13	Temperature	-	-	-	-
14	Bacterial count (MPN)	16	0	-	-

S.D. Jadhav  
Chemist  
Bhavani Peth WTP

Scanned with OKEN Scanner