



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasalheb varad path, Solapur-413003  
Email - [smcpheutr@gmail.com](mailto:smcpheutr@gmail.com) Tel.no.0217-2740350

PHE/BHIMA- 1462

दि. 5/4 /2024

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.1	0.7	1.0	5.0
4	pH Values	8.26	7.84	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	74.97	69.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	170	160	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	180	175	200	600
9	Total Dissolved Solids	412	417	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	1.6	6.0	6.5	8.0
12	Bacterial count (MPN)	16	0		

Chemist  
Soregaon WTP