



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - [smephewr@gmail.com](mailto:smephewr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA- 1385

दि. 6/2/2024

## Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.8	0.6	1.0	5.0
4	pH Values	8.16	7.74	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	309.95	306.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	410	400	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	290	280	200	600
9	Total Dissolved Solids	1020	1026	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen.	—	—	6.5	8.0
11	Electrical conductivity	—	—		
12	Bacterial count (MPN)	—	—		

*R.S.H.*

Chemist

Soregaon WTP