



# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur - 413003


Email - [smdphewtr@gmail.com](mailto:smdphewtr@gmail.com)

Tel. no. 0217-2740350

Dt 04/08/2023

### Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Clear	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.4	0.6	1.0	5.0
4	pH Values	7.9	7.5	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	80	60	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	180	170	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	150	130	200	600
9	Total Dissolved Solids	302	307	500	2000
10	Residual chlorine	-	4 ppm		

  
Chemist  
Pakani WTP