



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuyan, Railway line, punyashlok appasaheb varad path, Solapur-413003


Email - [smdphewtr@gmail.com](mailto:smdphewtr@gmail.com)

Tel.no: 0217-2740350

Dt 06/12/2023

## Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Suspended particles	clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.7	0.7	1.0	5.0
4	pH Values	7.7	7.4	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	80	70	250	1000
6	Ammonia	0.0	0.0	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	180	160	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	120	110	200	600
9	Total Dissolved Solids	260	215	500	2000
10	Residual chlorine	-	4.00ppm		

  
Chemist  
Pakani WTP