



Date
12/3/25
Wednesday

Solapur Municipal Corporation, Solapur
Public Health Engineer Department
Indrabhuvan, Railway line, Punyashlok Appasaheb Varad Path, Solapur-413003
Email:- smcpheutr@gmail.com
Tel. no.- 0217-2740350

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clear	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.3	1	5
4	pH Values	7.6	7.2	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	74.97	69.97	250	1000
6	ammonia	0.0	0.0	45	No relaxation
7	Total Hardness (as CaCO ₃)	170	160	200	600
8	Alkalinity (as CaCO ₃)	150	140	200	600
9	Total Dissolved Solids	295	290	500	2000
10	Residual chlorine	—	3ppm	—	—

Shinde
Chemist

Pakani WTP

