



Dt. 19-11-2024

Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Email :- smcphewr@gmail.com

Tel.No.0217-2740350

Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Raw Water	Treated Water	DIS Specification 10500:2012 Normal Values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Colourless	colourless		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU).	1.8	0.5	1.0	5.0
4	pH Values	6.98	6.95	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	104.92	98.42	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	250	240	200	600
8	Alkalinity (as CaCO ₃)	90	85	200	600
9	Total Dissolved solids	281	289	500	2000
10	Residual chlorine	-	4.0	-	-
11	Dissolved Oxygen	-	-	6.5	8.0
12	Electrical conductivity	-	-	-	-
13	Temperature	-	-	-	-
14	Bacterial count (MPN)	16	0	-	-

S.O. Jadhav
Chemist
Bhavani Peth WTP

