



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasal eb varad path, Solapur-413003
Tel.no.0217-2740350
Email – smcpheutr@gmail.com

दि. 6/9/2024

PHE/BHIMA - 1633

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly turbid	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	25	0.5	1.0	5.0
4	pH Values	7.62	7.01	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	102.96	99.96	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	170	165	200	600
8	Alkalinity (as CaCO ₃)	180	170	200	600
9	Total Dissolved Solids	310	315	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	2.1	7.2	6.5	8.0
12	Bacterial count (MPN)	16	0		

R.S. A

Chemist
Soregaon WTP