



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasal eb varad path, Solapur-413003
Email - smcphewtr@gmail.com Tel.no.0217-2740350

PHE/BHIMA-1665

दि. 7/10/2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Clean	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	5.1	0.6	1.0	5.0
4	pH Values	7.72	7.84	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	109.95	104.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	180	170	200	600
8	Alkalinity (as CaCO ₃)	170	160	200	600
9	Total Dissolved Solids	308	314	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	2.1	7.2	6.5	8.0
12	Bacterial count (MPN)	-	-		

R.S.K

Chemist
Soregaon WTP