



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - [smcphewr@gmail.com](mailto:smcphewr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA-1367

दि. 22/1/2024

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.2	0.6	1.0	5.0
4	pH Values	8.16	7.74	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	302.95	297.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	390	380	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	290	285	200	600
9	Total Dissolved Solids	1015	1021	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	1.6	6.4	6.5	8.0
11	Electrical conductivity	-	-		
12	Temperature	-	-		
13	Bacterial count (MPN)	-	-		

*R.S.A.*  
Chemist  
Soregaon WTP