



सोलापुर महानगरपालिका, सोलापुर
ईंद्रभुवन, रेल्वे लाईन्स, पुण्यश्लोक आप्पासाहेब वारद पथ,
सोलापूर- ४१३००१
सार्वजनिक आरोग्य अभियंता यांचे कार्यालय
ई मेल : smcphewtr@gmail.com टेलिफोन नं:-०२१७-
२७४०३५०



जाक्र.साआअ/भीमा 16 23

Date : 28/8/24

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	turbid	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	220	0.5	1.0	5.0
4	pH Values	7.32	6.72	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	89.95	85.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	170	165	200	600
8	Alkalinity (as CaCO ₃)	150	140	200	600
9	Total Dissolved Solids	256	259	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	2.1	7.3	6.5	8.0
12	Bacterial count (MPN)	Samples taken & kept for incubation?			

R.S.H
Chemist
Soregaon WTP