



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasalheb varad path, Solapur-413003

Email - [smcpheotr@gmail.com](mailto:smcpheotr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA-1487

दि. २१/५/२०२४

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.5	1.0	5.0
4	pH Values	7.94	7.62	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	134.96	129.96	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	240	230	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	210	200	200	600
9	Total Dissolved Solids	430	436	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	1.6	6.5	6.5	8.0
12	Bacterial count (MPN)	-	-		

  
Chemist  
Soregaon WTP