



# Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - [smcpheutr@gmail.com](mailto:smcpheutr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA-1524

दि.29/5/2024

## Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.2	0.6	1.0	5.0
4	pH Values	8.06	7.74	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	152.95	149.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	270	265	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	260	250	200	600
9	Total Dissolved Solids	460	466	500	2000
10	Residual chlorine	-	4.5	--	--
11	Dissolved oxygen	1.8	6.5	6.5	8.0
12	Bacterial count (MPN)	Samples taken with proper			

precaut<sup>n</sup> & kept for incubat<sup>n</sup>

R.S. H

Chemist  
Soregaon WTP