



Dt-12-03-2025

# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan Railway Line, Panyashlok Appaszheb varad Peth, Solapur-413003

Email :- [smcpheivr@gmail.com](mailto:smcpheivr@gmail.com)

Tel.No.0217-2740350

### Water Testling Report Bhavani Peth WTP

Sr.No.	Test Parameter	Rnw Wnter	Treated Water	BIS Specification 10500:2012 Normal Values	
				Deslrable Limits	Permlssible Limits
1	Physical appearance	Slightly green	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU).	2.4	0.8	1.0	5.0
4	pH Values	7.2	7.3	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	97.48	94.97	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	260	250	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	100	95	200	600
9	Total Dissolved solids	287	294	500	2000
10	Residual chlorine	-	4.0	.	.
11	Dissolved Oxygen	-		6.5	8.0
12	Electrical conductivity	-			
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S.D. Jadhav  
Chemist  
Bhavani Peth WTP