



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email – smcphewtr@gmail.com

Tel.no.0217-2740350

PHE/BHIMA- 8

दि. 17/2/2025

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	5.2	0.5	1.0	5.0
4	pH Values	8.16	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	326.95	322.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	370	360	200	600
8	Alkalinity (as CaCO ₃)	300	290	200	600
9	Total Dissolved Solids	660	664	500	2000
10	Residual chlorine	—	4.5	--	--
10	Dissolved oxygen	2.1	7.1	6.5	8.0
11	Bacterial count (MPN)	—	—		

Chemist
Soregaon WTP