



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003  
Email – [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com) Tel.no.0217-2740350

PHE/BHIMA- 22

दि. 31/3/2025P

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	01 Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	5.2	0.6	1.0	5.0
4	pH Values	8.01	7.64	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	324-90	320-90	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	360	350	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	330	320	200	600
9	Total Dissolved Solids	751	756	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	2.1	7.2	6.5	8.0
12	Bacterial count (MPN)	—	—		

R.S.H

Chemist  
Soregaon WTP