



Solapur Municipal Corporation, Solapur  
Public Health Engineer Department

Indrabhuvan, Railway line, Punyashlok Appasaheb Varad Path, Solapur-413003

Email:- smcpheotr@gmail.com

Tel. no.- 0217-2740350

Date

19/12/25  
Jadnosda

### Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical apperance	cloud	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.5	0.5	1	5
4	pH Values	7.6	7.3	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	69.97	64.97	250	1000
6	ammonia	0.0	0.0	45	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	170	160	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	140	130	200	600
9	Total Disolved Solids	259	264	500	2000
10	Residual chlorine	—	3ppm	—	—

*Bhinde*  
Chemist

Pakani WTP

