



Dt - 15 - 11 - 2024

# Solapur Municipal Corporation, Solapur

## Public Health Engineer Department

Indrabhuvan Railway Line, Punyashlok Appasaheb varad Peth, Solapur-413003

Tel.No.0217-2740350

Email :- [smcphewtr@gmail.com](mailto:smcphewtr@gmail.com)

### Water Testing Report Bhavani Peth WTP

Sr.No.	Test Parameter	Rnw Wnter	Treated Water	BIS Specification 10500:2012 Normal Values	
				Deslrable Limits	Permissible Limits
1	Physical appearance	colourless	colourless		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.3	0.7	1.0	5.0
4	pH Values	7.08	7.09	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	112.48	110.92	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO <sub>3</sub> )	260	250	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	90	85	200	600
9	Total Dissolved solids	269	272	500	2000
10	Residual chlorine	-	4.0	.	.
11	Dissolved Oxygen	-		6.5	8.0
12	Electrical conductivity	-			
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S. D. Jadhav  
Chemist

Bhavani Peth WTP