



Dt - 24-01-2025

Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan Railway Line, Purnyashlok Appasaheb varad Peth, Solapur-413003

Email: smcphewtr@gmail.com

Tel No.0217-2740350

Water Testing Report Bhavani Peth WTP

Sr. No.	Test Parameter	Raw Water	Treated Water	BIS Specification 10500:2012 Normal Values	
				Destrable Limits	Permlssible Limits
1	Physical appearance	slightly green	clean		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.2	0.6	1.0	5.0
4	pH Values	7.02	7.08	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	110.97	112.48	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total hardness (as CaCO ₃)	260	250	200	600
8	Alkalinity (as CaCO ₃)	90	85	200	600
9	Total Dissolved solids	272	279	500	2000
10	Residual chlorine	-	4.0		
11	Dissolved Oxygen	-			
12	Electrical conductivity	-		6.5	8.0
13	Temperature	-			
14	Bacterial count (MPN)	16	0		

S. D. Jadhav

Chemist
Bhavani Peth WTP