



Solapur Municipal Corporation, Solapur  
Public Health Engineer Department

Indrabhuvan, Railway line, Punyashlok Appasaheb Varad Path, Solapur-413003  
Email:- smcpheutr@gmail.com

Tel. no.- 0217-2740350

Date  
1/12/2025  
Saturday

### Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	clear	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.5	1	5
4	pH Values	7.6	7.2	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	66.30	62.10	250	1000
6	ammonia	0.0	0.0	45	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	170	160	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	160	150	200	600
9	Total Disolved Solids	248	254	500	2000
10	Residual chlorine	—	3 ppm	--	--

*Bhinde*

**Chemist**

**Pakani WTP**