

Date
14/2/25
Friday



Solapur Municipal Corporation, Solapur
Public Health Engineer Department
Indrabhuvan, Railway line, Punyashlok Appasaheb Varad Path, Solapur-413003
Email:- smophewtr@gmail.com
Tel. no.- 0217-2740350

Water testing report of Pakani WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012	
				Desirable Limits	Permissible Limits
1	Physical apperance	clear	clear		
2	Odour	odourless	odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	2.9	0.4	1	5
4	pH Values	7.6	7.2	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	69.97	64.97	250	1000
6	ammonia	0.00	0.00	45	No relaxation
7	Total Hardness (as CaCO3)	170.01	160.01	200	600
8	Alkalinity (as CaCO3)	160.01	150.01	200	600
9	Total Disolved Solids	260.0	265.0	500	2000
10	Residual chlorine	1.19	3 ppm	-	-

Y. Shinde
Chemist

Pakani WTP