



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003
Email – smcphewtr@gmail.com Tel.no.0217-2740350

PHE/BHIMA-1580

दि. 17/7/2024

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
			01		
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	3.2	0.6	1.0	5.0
4	pH Values	8.16	7.84	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	187.95	184.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	330	325	200	600
8	Alkalinity (as CaCO ₃)	240	230	200	600
9	Total Dissolved Solids	630	636	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	1.9	6.7	6.5	8.0
12	Bacterial count (MPN)	—	—		

R.S.K.

Chemist
Soregaon WTP