



## Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasal eb varad path, Solapur-413003

Email – [smcpheutr@gmail.com](mailto:smcpheutr@gmail.com)

Tel.no.0217-2740350

PHE/BHIMA - 1635

दि. 9/9/2024

### Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly turbid	Clean		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	20	0.6	1.0	5.0
4	pH Values	7.54	7.14	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	104.95	101.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO <sub>3</sub> )	180	175	200	600
8	Alkalinity (as CaCO <sub>3</sub> )	170	160	200	600
9	Total Dissolved Solids	316	319	500	2000
10	Residual chlorine	—	4.5	--	--
11	Dissolved oxygen	2.1	7.2	6.5	8.0
12	Bacterial count (MPN)	—	—		

Chemist  
Soregaon WTP