



Solapur Municipal Corporation, Solapur

Public Health Engineer Department

Indrabhuvan, Railway line, punyashlok appasaheb varad path, Solapur-413003

Email - smepheutr@gmail.com


Tel.no.0217-2740350

PHE/BHIMA- 1699

दि. 13/2/2025

Water testing report of Soregaon WTP

Sr.No	Test Parameter	Raw Water	Treated Water	BIS Specification 10500 : 2012 Normal values	
				Desirable Limits	Permissible Limits
1	Physical appearance	Slightly greenish	Clear		
2	Odour	Odourless	Odourless	Agreeable	Agreeable
3	Turbidity (as NTU)	4.2	0.5	1.0	5.0
4	pH Values	8.06	7.67	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	316.95	309.95	250	1000
6	Ammonia	Absent	Absent	0.5	No relaxation
7	Total Hardness (as CaCO ₃)	360	350	200	600
8	Alkalinity (as CaCO ₃)	310	300	200	600
9	Total Dissolved Solids	625	630	500	2000
10	Residual chlorine	-	4.5	--	--
10	Dissolved oxygen	2.9	7.6	6.5	8.0
11	Bacterial count (MPN)	Samples taken & kept for incubation			


Chemist
Soregaon WTP